



Certificate of Compliance

CERTIFICATE

Applicant: Victron Energy B.V.
De Paal 35
1351 JG Almere
The Netherlands

Product: Storage System

Model: MultiPlus-II 48/3000/35-32
MultiPlus-II 48/3000/35-32 GX
MultiPlus-II 48/5000/70-50
MultiPlus-II 48/5000/70-50 GX
MultiPlus-II 24/3000/70-32
MultiPlus-II 24/3000/70-32 GX

Intended use:

Automatic disconnection device with single-phase mains surveillance in accordance with IEC 62116 for photovoltaic systems with single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

SOP-9-1_14 GCC Certification Program, 11/20

Based on:

IEC 62116:2014

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 17PP264-25

Certificate No: 20-128-02

Date of issue: 2021-02-17

Kiwa Primara GmbH
Gewerbestraße 28
87600 Kaufbeuren
Germany
Tel. +49 8341 99726-0
info@primara.net
www.kiwa.de



Tanja Rottach
Certification Engineer